

Fire safety certificate



NEW



FORM B 13.3

FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 29)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOVMC/2021/00012052
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOVMC/2021/00012052/R1

Date: 08/06/2024

Building Occupancy/Category: Educational (non-residential)

To,

SHAH ALAP

VEMALI BUILDING VEMALI SAMA SAVLI ROAD VADODARA Vadodara MC 390008

Fire Region: Vadodara MC

Mobile No: 9825305515 Email ID: aalap4u@hotmail.com

This has reference to your Application No.2024/00061867 dated 03/06/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise AMBE PUBLIC SCHOOL (name of the Building/ Project), as per below mentioned details:


1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: VADODARA
5. Name of Block(s): AMBE PUBLIC SCHOOL

The building/premise was inspected on 08/06/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GPP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 08/06/2024
2. Six monthly inspection was done on 08/06/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 08/06/2026 in accordance with GPP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Darshankumar Bimalkumar Trivedi
Fire Safety Officer - General (FSO-G)
2021/000019

Date: 08/06/2024
Time: 08:17 PM




FSCA/O/CFOVMC/2021/00012052/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.


Principal
AMBE PUBLIC SCHOOL
Vadodara.


AMBÉ PUBLIC SCHOOL
Vemali
Sama-Savli Road,
Vadodara.